



CLARIFICATIONS FOR THE SUPPLY OF SIX (6) UNITS OF PORTABLE TEST EQUIPMENT TO THE LOSS CONTROL UNIT OF THE ELECTRICITY COMPANY OF GHANA (ECG)

RFP: 5130200-06/ICB/01/18

SI	Ref	Question	Answer
1	SR3	Could you please specify the application and location of use for the Portable Test Equipment? Will the equipment be used in the field or for laboratory Calibration purposes?	The equipment shall generally be used in the field for calibrating customer energy meters as part of activities in verifying actual customer demand, identification of illegal connections (power theft), etc. under the Commercial Loss Reduction Program.
2	SR3	Please confirm if 0.05% accuracy is required, as this level of accuracy is only required for laboratory use.	0.05% Power/energy measurement accuracy (or better) is required. It should be noted that precision measurements are required in revenue metering for the avoidance of doubts and potential litigations, especially for bulk power consumers.